



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION

CHRIS CHRISTIE
Governor
KIM GUADAGNO
Lt. Governor

Northern Bureau of Water Compliance and Enforcement
7 Ridgedale Avenue
Cedar Knolls, New Jersey 07927-1112
Telephone (973) 656-4099 Fax (973) 656-4400

BOB MARTIN
Commissioner

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
7011 3500 0001 9043 4075

May 1, 2013

Robert Chozick, Vice President
Forest Lakes Water Company
P.O. Box 264
Andover, NJ 07821

Re: Administrative Consent Order Termination
Forest Lakes Water Company
PW ID No. 1904003
NJEMS Document No. NEA110001
Byram Township, Sussex County

Dear Mr. Chozick:


The New Jersey Department of Environmental Protection (Department) and the Forest Lakes Water Company (Forest Lakes) entered into an Administrative Consent Order (ACO) with an effective date of March 2, 2012. The ACO established a Compliance Construction Schedule for the installation of auxiliary power at both the Forest Lakes Drive Booster Station and treatment plant (TP001003) to comply with auxiliary power requirements in accordance with N.J.A.C. 7:10-11.6.

Forest Lakes has since complied with the schedule set forth in the ACO by completing the installation of auxiliary power at the Forest Lakes Drive Booster Station and TP001003. Therefore, the Department is hereby notifying Forest Lakes that, pursuant to paragraph 36 of the ACO, Forest Lakes has demonstrated, to the satisfaction of the Department, that all terms of the ACO have been completed and therefore, the ACO is hereby terminated.

Paragraph 10 of the ACO required the submittal of quarterly progress reports. Please be advised that this ACO termination will relieve Forest Lakes of its obligation to submit further Progress Reports.

If you have any questions concerning this correspondence, please contact Frank M. Panico, of the Northern Bureau of Water Compliance and Enforcement, at (973) 656-4099.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Richard T. Paull". The signature is written in black ink and is positioned above the typed name.

Richard T. Paull, Bureau Chief
Northern Bureau of Water
Compliance and Enforcement

- c: Marcedius T. Jameson, Director, Division of Water and Land Use Enforcement
Karen Fell, Acting Assistant Director, Water System Operations Element
Diane Zalaskus, Bureau Chief, Bureau of Water Systems Engineering
Sandy Krietzman, Bureau Chief, Bureau of Safe Drinking Water